NARAINGARH SUGAR MILLS LTD., SHAHZADPUR, TEH. NARAINGARH

Detailed Notice Inviting Tender

Tender is invited for below mentioned items / jobs:-

Sr. No.	Description of items / jobs			Expiry Date & Time of Bid Preparation & Submission
1.	Supply of PT [potential transformer]	7,000/-	04.07.25 at 03:00 PM	18.07.25 upto 03:00 PM

Under this process, the Pre-qualification / Technical bid Application as well as Commercial Bid are invited at single stage under two covers i.e. Pre-qualification / Technical & Commercial Envelope. Eligibility and qualification of the Applicant will be first examined based on the details submitted under first envelope (Pre-qualification / Technical) with respect to eligibility and qualification criteria prescribed in this Tender document. The Commercial bid under the second envelope shall be opened for only those Applicants whose Pre-qualification / Technical bid Applications are responsive to eligibility and qualifications requirements as per Tender document.

- **Earnest Money:** The party will deposit the earnest money (mentioned above in table) by RTGS/NEFT before expiry date. The tender will not be accepted without earnest money.
- Bank details for Earnest Money:

Name: Naraingarh Sugar Mills Ltd. Bank A/c No. 913020056279987

Bank Name: Axis Bank Ltd.

Branch Name: Banaundi BNU HR, Banaundi-134202

IFSC Code: UTIB0002249

Note: The bids shall be submitted in two separate envelopes.

Signature of the party with seal
Name of the party:
Address:
Contact No

NARAINGARH SUGAR MILLS LTD., SHAHZADPUR, TEH. NARAINGARH

• Envelope 1: Pre-Qualification / Technical Bid

Sr. No.	Description			Quantity Required			
1	66Kv PT (Potential Transformer)					01No.	
	STANDAR	STANDARD: IS -3156/1992		PT RATIO: 66KV/ROOT3 /110V/ROOT3-/110V/ROOT3			
	HIGHEST	HIGHEST SYSTEM VOLTAGE: 72.5kV		RATED PRIMARY VOLTAGE: 66KV/ROOT3			
	INSULATION LEVEL: 140KV/325KV(P)		RATED V.F.: 1.2 Cont. & 1.5 For 30 sec				
	FREQUENCY: 50HZ		50HZ				1
	MIN. CREAPAGE DISTANCE: 18		1815mm			1	
	SUTABLE	SUTABLE FOR HOT LINE WASHING		NEYTRAL: EART	HED		
	WDG.	RATIO	PURPOSE	CLASS		BURDEN	1
	W1	66KV/ROOT3/110V/ROOT3	METERING	0.2		10 VA	1
	W2	66KV/ROOT3/110V/ROOT3	METERING	0.2		10 VA	1
		RATION SELECTION		SECONDA	RY SELECTION	I	1
				W1		W2	1
	66KV/ROOT3/110V/ROOT3		1a-1n		2a-2n		
			lectrical & Me		rt ltd		1
2	Make: Ka	pco ElectriC (P) LTD./MEHRU E (Potential Transformer)	l lectrical & Me		rt ltd		01No.
2	Make: Ka	pco ElectriC (P) LTD./MEHRU E	lectrical & Me	chnical Engineers pv		/ROOT3-/110V/ROOT3	01No.
2	Make: Ka 66Kv PT STANDAR	pco ElectrIC (P) LTD./MEHRU E (Potential Transformer)	lectrical & Me	chnical Engineers pv	ROOT3 /110V/	/ROOT3-/110V/ROOT3	01No.
2	Make: Ka 66Kv PT STANDAR HIGHEST	pco ElectrIC (P) LTD./MEHRU E (Potential Transformer) RD: IS -3156/1992	lectrical & Me	PT RATIO: 66KV/F	ROOT3 /110V/	/ROOT3-/110V/ROOT3 XV/ROOT3	01No.
2	Make: Ka 66Kv PT STANDAF HIGHEST INSULATI	(Potential Transformer) RD: IS -3156/1992 SYSTEM VOLTAGE: 72.5kV	lectrical & Me	PT RATIO: 66KV/F	ROOT3 /110V/ OLTAGE: 66F	/ROOT3-/110V/ROOT3 XV/ROOT3	01No.
2	Make: Ka 66Kv PT STANDAF HIGHEST INSULATI FREQUEN	(Potential Transformer) RD: IS -3156/1992 SYSTEM VOLTAGE: 72.5kV ON LEVEL: 140KV/325KV(P)	lectrical & Me	PT RATIO: 66KV/F	ROOT3 /110V/ OLTAGE: 66F	/ROOT3-/110V/ROOT3 XV/ROOT3	01No.
2	Make: Ka 66Kv PT STANDAF HIGHEST INSULATI FREQUEN MIN. CRE	(Potential Transformer) RD: IS -3156/1992 SYSTEM VOLTAGE: 72.5kV ON LEVEL: 140KV/325KV(P) ICY: 50HZ	lectrical & Me	PT RATIO: 66KV/F	ROOT3 /110V/ OLTAGE: 66F	/ROOT3-/110V/ROOT3 XV/ROOT3	01No.
2	Make: Ka 66Kv PT STANDAF HIGHEST INSULATI FREQUEN MIN. CRE	(Potential Transformer) RD: IS -3156/1992 SYSTEM VOLTAGE: 72.5kV ON LEVEL: 140KV/325KV(P) ICY: 50HZ APAGE DISTANCE: 1815mm	lectrical & Me	PT RATIO: 66KV/F RATED PRIMARY V RATED V.F.: 1	ROOT3 /110V/ OLTAGE: 66F	/ROOT3-/110V/ROOT3 XV/ROOT3 For 30 sec	01No.
2	66Kv PT STANDAF HIGHEST INSULATI FREQUEN MIN. CRE SUTABLE	(Potential Transformer) RD: IS -3156/1992 SYSTEM VOLTAGE: 72.5kV ON LEVEL: 140KV/325KV(P) ICY: 50HZ APAGE DISTANCE: 1815mm FOR HOT LINE WASHING	lectrical & Me	PT RATIO: 66KV/F RATED PRIMARY V RATED V.F.: 1 NEYTRAL:	ROOT3 /110V/ OLTAGE: 66F	/ROOT3-/110V/ROOT3 XV/ROOT3 For 30 sec EARTHED	01No.
2	Make: Ka 66Kv PT STANDAR HIGHEST INSULATI FREQUEN MIN. CRE SUTABLE WDG.	(Potential Transformer) RD: IS -3156/1992 SYSTEM VOLTAGE: 72.5kV ON LEVEL: 140KV/325KV(P) ICY: 50HZ APAGE DISTANCE: 1815mm FOR HOT LINE WASHING RATIO	lectrical & Me	PT RATIO: 66KV/F RATED PRIMARY V RATED V.F.: 1.: NEYTRAL: CLASS	ROOT3 /110V/ OLTAGE: 66F	(ROOT3-/110V/ROOT3 (V/ROOT3 For 30 sec EARTHED BURDEN	01No.
2	Make: Ka 66Kv PT STANDAF HIGHEST INSULATI FREQUEN MIN. CRE SUTABLE WDG. W1	(Potential Transformer) RD: IS -3156/1992 SYSTEM VOLTAGE: 72.5kV ON LEVEL: 140KV/325KV(P) ICY: 50HZ APAGE DISTANCE: 1815mm FOR HOT LINE WASHING RATIO 66KV/ROOT3/110V/ROOT3	lectrical & Me	PT RATIO: 66KV/F RATED PRIMARY V RATED V.F.: 1.: NEYTRAL: CLASS 0.2 3P	ROOT3 /110V/ OLTAGE: 66F	(ROOT3-/110V/ROOT3 (V/ROOT3 For 30 sec EARTHED BURDEN 100 VA	01No.
2	Make: Ka 66Kv PT STANDAF HIGHEST INSULATI FREQUEN MIN. CRE SUTABLE WDG. W1	(Potential Transformer) RD: IS -3156/1992 SYSTEM VOLTAGE: 72.5kV ON LEVEL: 140KV/325KV(P) ICY: 50HZ APAGE DISTANCE: 1815mm FOR HOT LINE WASHING RATIO 66KV/ROOT3/110V/ROOT3 66KV/ROOT3/110V/ROOT3	lectrical & Me	PT RATIO: 66KV/F RATED PRIMARY V RATED V.F.: 1.: NEYTRAL: CLASS 0.2 3P	ROOT3 /110V/ OLTAGE: 66H 2 Cont. & 1.5	(ROOT3-/110V/ROOT3 (V/ROOT3 For 30 sec EARTHED BURDEN 100 VA	01No.

Bid shall be accepted on the basis of above mentioned specifications.

The bidders shall submit the required eligibility documents in the Pre-qualification / Technical Bid having following documents.

<u>Information</u> /documents to be attached by the tenderers with the Pre-qualification / Technical Bid where ever is applicable.

- Copy of latest three year purchase / work order of firms / companies for the same type of materials /Jobs.
- Certificate of authorized dealership of particular material, if party is authorized.
 (For supplier only)

- 3) Certificate from the proprietor/partner/firm authorizing firm's representative to sign/participate in opening and negotiation of the tender (signature duly attested).
- 4) Copy of Sales Tax/GST registration number.
- 5) Copy of PAN Card.
- 6) The information i.e. Firm/Company Name, Complete Address, Contact person, Mobile No. & email ID to be attached.
- 7) EMD or RTGS/NEFT details.

In case of Non-attachment of the above (wherever is applicable) this bid shall be reject	ted.
Declaration:-	
We declare that we have put up the commercial bid as per format & no change in cond	ditions has
been mentioned, the conditions mentioned there in are acceptable to us.	
Ē	Please tick
Signature of the party with seal	
Name of the party:	
Address:	
Contact No	

NARAINGARH SUGAR MILLS LTD., SHAHZADPUR, TEH. NARAINGARH

• Envelope 2: Commercial Bid

The bidders shall quote the prices in Commercial bid format under

(COMMERCIAL BID TO BE SUBMIT)

Sr. No.	Description	Qty. in No.	Unit Rates INR.
1	66Kv PT (Potential Transformer) Complete technical specification (Sr. No. 1) Mentioned in technical bid	01	
2	66Kv PT (Potential Transformer) Complete technical specification (Sr. No. 2) Mentioned in technical bid	01	

Terms & Conditions:-

- 1) Payment terms:
 - a) For material supply: 30 days after receipt of material subjected to quality approved.
 - b) For job work: 30 days after submission of verified bills subjected to satisfactory completion of work.
- 2) Price will be FOR Naraingarh Sugar Mills Ltd.
- 3) Packing & forwarding charges: In the scope of supplier / Contractor.
- 4) Please mention the time period of material delivery / job completion in given space under:-

- 5) SGST/CGST/UGST/IGST will be extra as applicable as per norms (Our GST No.06AAACN0454G1ZV).
- 6) TDS to be deducted as per GST Rules (if applicable).
- 7) It will be mandatory condition, that no employee/his family member / relative can take participate directly or indirectly in BID.
- 8) Presence of BIDDER by self in case of proprietor/ Partner or Authorized person with authority letter in case of partnership/Co. is necessary at the time of opening of tender is must.
- 9) **Liquidated Damages:** Time is the essence of this supply / job. Hence, you shall strictly adhere to the delivery of material / completion of job. You are liable to pay liquidated damages towards late delivery of the material / late completion of job at the rate of 2% of the value of the order for subject supply / job for the delay of every one week subject to the maximum limit of 10% of the value of the Order.

- 10) If at all L-1 party refuses to undertake the job, then purchase committee shall have the right to award the order to second lowest party on the finalized rates in the interest of the Mills.
- 11) Board/Management of the Mills shall have the right to negotiate with other participants also if quoted rates of L-1, L-2 & L-3 party do not seem to be reasonable upto the marks in the interest of the Mills.
- 12) Rates are to be quoted on the basis of above said terms & conditions.
- 13) Conditional tender will not be accepted.
- 14) The undersigned reserves the right to accept or reject any or all the tenders without assigning any reason.

Note: Only Pre-qualification / Technical bid will be open by our technical team for discussion. Parties are invited on opening of commercial bid on dated 22.07.25 at 11:00 AM.

Signature of the party with seal	
Name of the party:	
Address:	
Contact No	